

Technical Interpretation Policy Committee

November 29, 2011

12:00 pm – 1:00 pm ET

Chair: Tom Culp, Birch Point Consulting, LLC

Vice Chair: Michael Thoman, Architectural Testing, Inc.

Staff Liaison: Dennis Anderson

Minutes

- Roll Call at 12:06 PM ET:

COMPANY	NAME	PRESENT
Birch Point Consulting, LLC	Tom Culp (Chair)	Y
Architectural Testing, Inc.	Mike Thoman	Y
WESTLab	Jeff Baker	N
AMSCO Windows	Joe Jonely	Y
LBNL	Charlie Curcija	Y
Associated Labs, Inc.	Brad Schultz	Y
EFCO	Joseph Holmes	N
Andersen Corporation	Steve Johnson	Y

- Agenda reviewed and approved
- October 25, 2011 conference call minutes and Atlanta Membership Meeting minutes approved.
MOTION: J. Jonely / S. Johnson moved to approve October 25, 2011 and Atlanta Membership Meeting minutes. Motion passed 6-0.
- Unfinished Business: None
- New Business:
 - Reviewed TIR-2011-18 Steel Frame Boundary Conditions. This TIR was discussed and it was agreed to revise steel to metallic frames and also modified the interpretation to reference aluminum boundary conditions and the use of NFRC 101, as appropriate.
MOTION: M. Thoman / C. Curcija moved to approve TIR-2011-18, as modified. Motion passed 6-0.
 - TIPC reviewed TI-2010-06 Custom Skylights and compared it to the approved Commercial Skylights Ballot from the Atlanta Meetings to ensure that rescinding this TI from the 2010 TI Manual will not prevent simulating/testing of custom skylights that was referenced in the TI-2010-06. It was determined that all commercial skylights were covered satisfactorily in the approved balloted language and TI-2010-06 will be rescinded.
 - It was noted by Staff that a TIR is under development regarding the clarification of grouping rules for Center-of-Glass and Dividers/Grids.
- Next call scheduled for Monday, December 19 at 11:00 PM ET.
- Adjourned at 12:48 PM ET.