



## NFRC PCP Bulletin 2009-07

---

**DOCUMENTS:** NFRC 700-2009  
**DATE:** October 6, 2009  
**SUBJECT:** Clarification on labeling blinds between the glass options

---

This bulletin relates to clarifying the labeling of options containing blinds between the glass.

If you have any questions concerning the information in the *NFRC Bulletin*, please contact Scott Hanlon at 240-821-9519; email: [shanlon@nfr.org](mailto:shanlon@nfr.org).

---

### **Item 1: Labeling options with blinds between the glass**

The CPC has determined that products containing blinds between the glass shall be rated in the following manner:

1. For options labeling only one of the positions (Open or Closed) a temporary label per Figure B-1 of NFRC 700-2009, a dynamic label **shall not** be used. This would apply to an option containing a blind in the Fully Open / Up position only, modeled using the simulation procedure.
2. An option containing a blind in the Fully Open / Up and Fully Closed / Down positions, modeled using the simulation procedure for the open position and the center-of-glass component test procedure per Section 4.3.2.2 of the NFRC 100, shall be rated using a temporary dynamic label per Figure B-3 of NFRC 700-2009.

This bulletin is in relation to the NFRC Board of Directors approval, to suspend the certification and labeling deadline of dynamic glazing products of March 1, 2010 and that this topic will be brought forth to the Board at the November 2009 membership meeting at which time a mandatory deadline date will be determined.