



PCPI-2008-01 05/20/2008
----------------------------

## **NFRC PCP Interpretation – 2008**

<b><i>Interpretation Requested:</i></b>
Can NFRC’s permanent labeling requirements be met by placing the required information on a permanent label beneath a stop or glazing bead?

<b><i>Date Requested</i></b>	<b><i>Initial Interpretation Date</i></b>	<b><i>Final APC Approval Date</i></b>
03/19/2008	04/17/2008	05/20/2008

<b><i>Pertinent Document:</i></b>	
PCP-2008	
<b><i>Referenced Sections:</i></b>	<b><i>Referenced Pages:</i></b>
6.7	

<b><i>Interpretation:</i></b>
Yes, the location of this permanent label shall be in a consistent location as identified by the manufacturer in the NFRC CPD.

<b><i>Certification Policy Committee Revisions to Initial Interpretation:</i></b>